	WELL	CONSTRUCT	OR'S REPORT	TO WISC	CONSIN STATE BOARD	OF HEALTH	مميد	
1. County Gankee (Town Village Cedantura								
2. Location SW. 4 of n. W. 4 Sec 34 Lown 100 Range 21 E								
3. Owner or Agent alfred Lookman								
4. Address Cedantura, Wis.								
5. Sewer — ft; drain — ft; septic tank — ft; disposal unit — ft; barn-yard — ft; abandoned well — ft; other <u>so</u> ft. Explain on obverse side.								
	DRILLHO Dia. (in.)	OR EXC. From (ft.)	AVATION To (ft.)	CASI Dia. (in.)	NG PIPE, LINER PIPE Kind	OR CURBI	ING To (ft.)	
 ,	10	0	35	<u></u>	Stel out Steel	0	86	
	6	35	116	1				
				· · · · · · · · · · · · · · · · · · ·				
	· 							
FORMATIONS								
			From	To	GROUT From To			
	Kind		(ft.)	(ft.)	Kind	(ft.)	(ft.)	
Play			4 D	mud		40		
Hardpen		40	86	<u> </u>				
		f						
					<u> </u>			
	······	· · · · · · · · · · · · · · · · · · ·		···	<u> </u>			
					Yield test: 5 Hrs. at /5 GPM. To static water-level 62 ft.			
								
					Drawdown <u>b</u> ft.			
					Water sample was sent to the State Laboratory at Madison Construction of the well was completed on Gay. 28 1949 The well is terminated incies			
								
				·····				
				· · · · · · · · · · · · · · · · · · ·	(above)(below) the permanent grade.			
					Was the well disinfected upon completion? Yes ✓ No			
				· · · · · · · · · · · · · · · · · · ·				
					Registered Well Driller			
				(over)	Permit No.33 Dat	E 11/24	1944	
a sellis tili	BI BIJAK BIJAKI JABA ibiri			,				